

In view of these criteria, the Highways and Lead Local Flood Authority does not consider that this proposal would result in a severe impact with regard to NPPF.

Highway Condition 33

The permitted development shall be undertaken in accordance with a surface water drainage scheme which shall first have been approved in writing by the Local Planning Authority.

The scheme shall:

- be based on sustainable drainage principles and an assessment of the hydrological and hydrogeological context of the development;
- provide flood exceedance routing for storm event greater than 1 in 100 year;
- provide details of how run-off will be safely conveyed and attenuated during storms up to and including the 1 in 100 year critical storm event, with an allowance for climate change, from all hard surfaced areas within the development into the existing local drainage infrastructure and watercourse system without exceeding the run-off rate for the undeveloped site;
- provide attenuation details and discharge rates which shall be restricted to 1.4 litres per second/per hectare;
- provide details of the timetable for and any phasing of implementation for the drainage scheme; and
- provide details of how the scheme shall be maintained and managed over the lifetime of the development, including any arrangements for adoption by any public body or Statutory Undertaker and any other arrangements required to secure the operation of the drainage system throughout its lifetime.

No dwelling shall be occupied until the approved scheme has been completed or provided on the site in accordance with the approved phasing. The approved scheme shall be retained and maintained in full, in accordance with the approved details.

To ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, or upstream of, the permitted development.

Highway Condition 00

No development shall take place until a Construction Management Plan and Method Statement has been submitted to and approved in writing by the Local Planning Authority which shall indicate measures to mitigate against traffic generation and drainage of the site during the construction stage of the proposed development.

The Construction Management Plan and Method Statement shall include;

- phasing of the development to include access construction;
- the parking of vehicles of site operatives and visitors;
- loading and unloading of plant and materials;
- storage of plant and materials used in constructing the development;
- wheel washing facilities;
- the routes of construction traffic to and from the site including any off site routes for the disposal of excavated material and;
- strategy stating how surface water run off on and from the development will be managed during construction and protection measures for any sustainable drainage features. This should include drawing(s) showing how the drainage systems (permanent or temporary) connect to an outfall (temporary or permanent) during construction.

The Construction Management Plan and Method Statement shall be strictly adhered to throughout the construction period.

Reason: To ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, the permitted development during construction and to ensure that suitable traffic routes are agreed.

Highway Condition 21

No part of the development hereby permitted shall be occupied (apart from those works identified on drawing number 132-BT-01 Rev H or as specified) before the works to improve the public highway (by means of an uncontrolled Tactile Crossing Point on Peterborough Road) have been certified complete by the Local Planning Authority.

To ensure the provision of safe and adequate means of access to the permitted development.

Highway Condition 26

Before any dwelling is occupied, all of that part of the estate road and associated footways that forms the junction with the main road and which will be constructed within the limits of the existing highway, shall be laid out and constructed to finished surface levels in accordance with details to be submitted to, and approved in writing by, the Local Planning Authority.

In the interests of safety, to avoid the creation of pedestrian trip hazards within the public highway from surfacing materials, manholes and gullies that may otherwise remain for an extended period at dissimilar, interim construction levels.

Highway Condition 29

The permitted development shall be undertaken in accordance with an Estate Road Phasing and Completion Plan, which shall first be approved in writing by the Local Planning Authority. The Plan shall set out how the construction of the development will be phased and standards to which the

estate roads on each phase will be completed during the construction period of the development.

To ensure that a safe and suitable standard of vehicular and pedestrian access is provided for residents throughout the construction period of the development.

Highway Informative 02

In accordance with Section 59 of the Highways Act 1980, please be considerate of causing damage to the existing highway during construction and implement mitigation measures as necessary. Should extraordinary expenses be incurred by the Highway Authority in maintaining the highway by reason of damage caused by construction traffic, the Highway Authority may seek to recover these expenses from the developer.

Highway Informative 05

All roads within the development hereby permitted must be constructed to a satisfactory engineering standard. Those roads that are to be put forward for adoption as public highways must be constructed in accordance with the Lincolnshire County Council Development Road Specification that is current at the time of construction and the developer will be required to enter into a legal agreement with the Highway Authority under Section 38 of the Highways Act 1980. Those roads that are not to be voluntarily put forward for adoption as public highways, may be subject to action by the Highway Authority under Section 219 (the Advance Payments code) of the Highways Act 1980. For guidance please refer to <https://www.lincolnshire.gov.uk>

Highway Informative 08

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections and any other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works. For further guidance please visit our website via the following links:

Traffic Management - <https://www.lincolnshire.gov.uk/traffic-management>

Licences and Permits - <https://www.lincolnshire.gov.uk/licences-permits>

Highway Informative 09

The existing ground level of the site must not be raised above the ground level of any surrounding land without further consultation with the Lead Local Flood Authority and Local Planning Authority, to consider suitable mitigation measures to ensure that surface water flood risk is not created or increased to land adjacent to the permitted development.

Highway Informative 07

The highway improvement works referred to in the above condition are required to be carried out by means of a legal agreement between the landowner and the County Council, as the Local Highway Authority.

Highway Informative 03

The permitted development requires the formation of a new/amended vehicular access. These works will require approval from the Highway Authority in accordance with Section 184 of the Highways Act. The works should be constructed in accordance with the Authority's specification that is current at the time of construction. Relocation of existing apparatus, underground services or street furniture will be the responsibility of the applicant, prior to application. For application guidance, approval and specification details, please visit <https://www.lincolnshire.gov.uk/licences-permits/apply-dropped-kerb> or contact vehiclecrossings@lincolnshire.gov.uk

Case Officer:

Sam Wood

**for Warren Peppard
Head of Development Management**

Date: 30 August 2022