

Warren Peppard
Head of Development Management
Lincolnshire County Council
County Offices
Newland
Lincoln LN1 1YL
Tel: 01522 782070
developmentmanagement@lincolnshire.gov.uk

To: West Lindsey District Council

Application Ref: 141839

Proposal: **Planning application to erect 80no. dwellings with associated car parking, gardens, roads, home-zones, pathways (foot and cycle) and public open space**

Location: **Land off Gallamore Lane, Middle Rasen, Market Rasen, LN8 3HZ**

With reference to the above application received 29 October 2020

Notice is hereby given that the County Council as Local Highway and Lead Local Flood Authority:

Requests that any permission given by the Local Planning Authority shall include the conditions below.

CONDITIONS (INCLUDING REASONS) /REASONS FOR REFUSAL

Highway Informative 03

The permitted development requires the formation of a new vehicular access. These works will require approval from the Highway Authority in accordance with Section 184 of the Highways Act. The works should be constructed in accordance with the Authority's specification that is current at the time of construction. Relocation of existing apparatus, underground services or street furniture will be the responsibility of the applicant, prior to application. For application guidance, approval and specification details, please visit <https://www.lincolnshire.gov.uk/licences-permits/apply-dropped-kerb> or contact vehiclecrossings@lincolnshire.gov.uk

Highway Informative 05

All roads within the development hereby permitted must be constructed to a satisfactory engineering standard. Those roads that are to be put forward for adoption as public highways must be constructed in accordance with the Lincolnshire County Council Development Road

Specification that is current at the time of construction and the developer will be required to enter into a legal agreement with the Highway Authority under Section 38 of the Highways Act 1980. Those roads that are not to be voluntarily put forward for adoption as public highways, may be subject to action by the Highway Authority under Section 219 (the Advance Payments code) of the Highways Act 1980. For guidance please refer to <https://www.lincolnshire.gov.uk>

Highway Informative 07

The highway improvement works referred to in the below condition are required to be carried out by means of a legal agreement between the landowner and the County Council, as the Local Highway Authority.

Highway Informative 08

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections and any other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works. For further guidance please visit our website via the following links:

Traffic Management - <https://www.lincolnshire.gov.uk/traffic-management>
Licences and Permits - <https://www.lincolnshire.gov.uk/licences-permits>

Highway Condition 00

No development shall take place until a Construction Management Plan and Method Statement has been submitted to and approved in writing by the Local Planning Authority which shall indicate measures to mitigate against traffic generation and drainage of the site during the construction stage of the proposed development.

The Construction Management Plan and Method Statement shall include;

- phasing of the development to include access construction;
- the parking of vehicles of site operatives and visitors;
- loading and unloading of plant and materials;
- storage of plant and materials used in constructing the development;
- wheel washing facilities;
- the routes of construction traffic to and from the site including any off site routes for the disposal of excavated material and;
- strategy stating how surface water run off on and from the development will be managed during construction and protection measures for any sustainable drainage features. This should include drawing(s) showing how the drainage systems (permanent or temporary) connect to an outfall (temporary or permanent) during construction.

The Construction Management Plan and Method Statement shall be strictly adhered to throughout the construction period.

Reason: To ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, the permitted development during construction and to ensure that suitable traffic routes are agreed.

Highway Condition 20

The development hereby permitted shall not be occupied before a 1.8 metre wide footway, to connect the development to the existing footway network on the north and south side of Gallamore Lane, has been provided in accordance with details that shall first have been submitted to, and approved in writing by, the Local Planning Authority. The works shall also include appropriate arrangements for the management of surface water run-off from the highway.

To ensure the provision of safe and adequate pedestrian access to the permitted development, without increasing flood risk to the highway and adjacent land and property.

Highway Condition 21

No part of the development hereby permitted shall be occupied before the works to improve the public highway by means of a pedestrian refuge island, has been provided in accordance with details that shall first have been submitted to, approved in writing by, and certified complete by the Local Planning Authority.

To ensure the provision of safe and adequate means of access to the permitted development.

Highway Condition 27

Business Travel Plan

Development shall not be commenced until a Travel Plan has been submitted to and approved in writing by the local planning authority. Those parts of the approved Travel Plan that are identified therein as being capable of implementation after occupation shall be implemented in accordance with the timetable contained therein and shall continue to be implemented as long as any part of the development is occupied.

To ensure that access to the site is sustainable and reduces dependency on the car.

Highway Condition 33

The permitted development shall be undertaken in accordance with a surface water drainage scheme which shall first have been approved in writing by the Local Planning Authority.

The scheme shall:

- be based on sustainable drainage principles and an assessment of the hydrological and hydrogeological context of the development;
- provide flood exceedance routing for storm event greater than 1 in 100 year;
- provide details of how run-off will be safely conveyed and attenuated during storms up to and including the 1 in 100 year critical storm event, with an allowance for climate change, from all hard surfaced areas within the development into the existing local drainage infrastructure and watercourse system without exceeding the run-off rate for the undeveloped site;
- provide attenuation details and discharge rates which shall be restricted to 13 litres per second;

- provide details of the timetable for and any phasing of implementation for the drainage scheme; and
- provide details of how the scheme shall be maintained and managed over the lifetime of the development, including any arrangements for adoption by any public body or Statutory Undertaker and any other arrangements required to secure the operation of the drainage system throughout its lifetime.

No dwelling shall be occupied until the approved scheme has been completed or provided on the site in accordance with the approved phasing. The approved scheme shall be retained and maintained in full, in accordance with the approved details.

To ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, or upstream of, the permitted development.

Notes:

There is no precise definition of "severe" with regards to NPPF Paragraph 111, which advises that "Development should only be prevented or refused on highways grounds if there would be an unacceptable impact on highway safety, or the residual cumulative impacts on the road network would be severe." Planning Inspector's decisions regarding severity are specific to the locations of each proposal, but have common considerations:

- The highway network is over-capacity, usually for period extending beyond the peak hours
- The level of provision of alternative transport modes
- Whether the level of queuing on the network causes safety issues.

In view of these criteria, the Highways and Lead Local Flood Authority does not consider that this proposal would result in a severe impact with regard to NPPF.

NO OBS

Having given due regard to the appropriate local and national planning policy guidance (in particular the National Planning Policy Framework), Lincolnshire County Council (as Highway Authority and Lead Local Flood Authority) has concluded that the proposed development is acceptable and accordingly, does not wish to object to this planning application.

Note to Officer:

The development triggers the extension of the existing 30mph speed limit and associated Traffic Regulation Order. A S106 sum of £5000 will be required so that the Highway Authority can process and implement this change.

A S106 sum of £5000 will be required for the future monitoring of any approved Travel Plan.

Case Officer:

John Clifton

Date: 22/04/2022

for Warren Peppard
Head of Development Management