

Warren Peppard  
Head of Development Management  
Lincolnshire County Council  
County Offices  
Newland  
Lincoln LN1 1YL  
Tel: 01522 782070  
developmentmanagement@lincolnshire.gov.uk

To: Boston Borough Council

Application Ref: B/22/0306

Proposal: **Outline application with some matters reserved (Appearance, Landscaping & Scale) for later approval for the erection of 45 dwellings**

Location: **Land off Tooley Lane, Wrangle, Boston, PE22 9BL**

With reference to the above application received 2 September 2022

Notice is hereby given that the County Council as Local Highway and Lead Local Flood Authority:

**Requests that any permission given by the Local Planning Authority shall include the conditions below.**

Highway Informative 05

All roads within the development hereby permitted must be constructed to a satisfactory engineering standard. Those roads that are to be put forward for adoption as public highways must be constructed in accordance with the Lincolnshire County Council Development Road Specification that is current at the time of construction and the developer will be required to enter into a legal agreement with the Highway Authority under Section 38 of the Highways Act 1980. Those roads that are not to be voluntarily put forward for adoption as public highways, may be subject to action by the Highway Authority under Section 219 (the Advance Payments code) of the Highways Act 1980. For guidance please refer to <https://www.lincolnshire.gov.uk>

Highway Informative 08

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections and any other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works. For further guidance please visit our website via the following links:

Traffic Management - <https://www.lincolnshire.gov.uk/traffic-management>  
Licences and Permits - <https://www.lincolnshire.gov.uk/licences-permits>

#### Highway Condition 00

The development hereby permitted shall be undertaken in accordance with a Construction Management Plan and Method Statement that shall first be approved in writing by the Local Planning Authority. The Plan and Statement shall indicate measures to mitigate the adverse impacts of vehicle activity and for the management of surface water run-off from the site during the construction stage of the proposed development. It shall include;

- the phasing of the development to include access construction;
- the on-site parking of all vehicles of site operatives and visitors;
- the on-site loading and unloading of all plant and materials;
- the on-site storage of all plant and materials used in constructing the development;
- wheel washing facilities;
- a strategy stating how surface water run off on and from the development will be managed during construction and protection measures for any sustainable drainage features. This should include drawing(s) showing how the drainage systems (permanent or temporary) connect to an outfall (temporary or permanent) during construction.

Reason: In the interests of the safety and free passage of those using the adjacent public highway and to ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, the permitted development during construction.

#### Highway Condition 29

The permitted development shall be undertaken in accordance with an Estate Road Phasing and Completion Plan, which shall first be approved in writing by the Local Planning Authority. The Plan shall set out how the construction of the development will be phased and standards to which the estate roads on each phase will be completed during the construction period of the development.

To ensure that a safe and suitable standard of vehicular and pedestrian access is provided for residents throughout the construction period of the development.

#### Highway Condition 33

The permitted development shall be undertaken in accordance with a surface water drainage scheme which shall first have been approved in writing by the Local Planning Authority.

The scheme shall:

- be based on sustainable drainage principles and an assessment of the hydrological and hydrogeological context of the development;
- provide flood exceedance routing for storm event greater than 1 in 100 year;

- provide details of how run-off will be safely conveyed and attenuated during storms up to and including the 1 in 100 year critical storm event, with an allowance for climate change, from all hard surfaced areas within the development into the existing local drainage infrastructure and watercourse system without exceeding the run-off rate for the undeveloped site;
- provide attenuation details and discharge rates which shall be restricted to 1.4 litres per second per hectare;
- provide details of the timetable for and any phasing of implementation for the drainage scheme; and
- provide details of how the scheme shall be maintained and managed over the lifetime of the development, including any arrangements for adoption by any public body or Statutory Undertaker and any other arrangements required to secure the operation of the drainage system throughout its lifetime.

No dwelling shall be occupied until the approved scheme has been completed or provided on the site in accordance with the approved phasing. The approved scheme shall be retained and maintained in full, in accordance with the approved details.

To ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, or upstream of, the permitted development.

Case Officer:

*Jon Sharpe*

**for Warren Peppard  
Head of Development Management**

Date: 12 September 2022