

LINCOLNSHIRE COUNTY COUNCIL'S RESPONSE TO CONSULTATION ON THE FOLLOWING DEVELOPMENT PROPOSAL

District: South Kesteven District Council

Application number: S23/0084

Application Type: Full

Proposal: Formation of lake and use of site for angling and open water swimming uses, erection of amenity building/changing room building and associated parking and access tracks

Location: Station Road, Deeping St James, Lincolnshire, PE6 8RH

Response Date: 7 February 2023

This report includes the Substantive response of the Local Highway and Lead Local Flood Authority to a planning consultation received under the Development Management Order and includes details of any planning conditions or informatives that should be attached in the event that permission is granted and any obligations to be secured by way of a S106 agreement.

General Information and Advice

Outline applications and contributions

The anticipated number and type of dwellings and/or the floor space may be set by the developer at the time of application which is used to assess necessary mitigation. If not stated in the application, a policy compliant mix will be used. The number and type of dwellings used when assessing S106 planning obligations is set out on the first page of this response.

In the case of outline applications, once the unit mix/floor space is confirmed by reserved matters approval/discharge of condition a matrix (if appropriate) will be applied to establish any increase in contributions payable. A further increase in contributions may result if there is a reserved matters approval changing the unit mix/floor space.

Please note that although the Definitive Map and Statement proves the existence of an recorded rights of way, there may be further or higher rights that are not shown on this document that the County Council is not currently aware of. This would be especially relevant where the public has had informal access to the site or where there are references to routes across this in maps or other historic documents. As the County Council has received no application to recognise further rights of way affecting the site, no more informed guidance can be offered at this stage.

Application number: S23/0084

Application Type: Full

Location: Station Road, Deeping St James, Lincolnshire, PE6 8RH

Highway and Lead Local Flood Authority Report

Substantive Response provided in accordance with article 22(5) of The Town and Country Planning (Development Management Procedure) (England) Order 2015:

Recommendation:

No objection subject to:

- **Planning Conditions** as detailed below.

Comments:

This application proposes the formation of an approximate 0.75ha angling/swimming lake within an approximately 4ha rectangular field situated on the eastern side of B1186 Station Road, Deeping St James.

Introduction/Site Location

The land is generally agricultural land. It is set on the eastern side of the overall site, back from the road frontage.

Highway safety/Highway capacity

There will be no adverse impact on the local highway network. The development will utilise an improved existing access point for vehicular access. Traffic generation will be modest, however, it is considered that the proposals would not result in an unacceptable impact on the highway network.

Site Layout

Adequate provision for car parking is proposed within the limits of the site.

Flood Risk and Drainage

As Lead Local Flood Authority, Lincolnshire County Council is required to provide a statutory planning consultation response with regard to Drainage on all Major Applications. The Lead Local Flood Authority does not consider that this proposal would increase flood risk in the immediate vicinity of the site.

Planning Conditions:

In the event that permission is to be given, the following planning conditions should be attached:

HP11A - Prior to first occupation on site further details relating to the vehicular access to the public highway, including materials, specification of works and construction method shall be submitted to the Local Planning Authority for approval. The approved details shall be implemented on site before the development is first brought in to use and thereafter retained at all times.

Reason: In the interests of safety of the users of the public highway and the safety of the users of the site.

Informatives

Highway Informative 03

The permitted development requires the formation of a new/amended vehicular access. These works will require approval from the Highway Authority in accordance with Section 184 of the Highways Act. Any traffic management required to undertake works within the highway will be subject to agreement. The access must be constructed in accordance with a current specification issued by the Highway Authority. Any requirement to relocate existing apparatus, underground services, or street furniture because of the installation of an access will be the responsibility, and cost, of the applicant and must be agreed prior to a vehicle access application. The application form, costs and guidance documentation can be found on our website, accessible via the following link: <https://www.lincolnshire.gov.uk/licences-permits/apply-dropped-kerb>.

Officer's Name: Sarah Heslam

Officer's Title: Principal Development Management Officer

Date: 7 February 2023