

LINCOLNSHIRE COUNTY COUNCIL'S RESPONSE TO CONSULTATION ON THE FOLLOWING DEVELOPMENT PROPOSAL

District: North Kesteven District Council

Application number: 22/1046/FUL

Application Type: Major

Proposal: Erection of 28 no. affordable dwellings and associated external works, including formation of access and demolition of 66 Jerusalem Road

Location: 66 Jerusalem Road, Skellingthorpe, Lincoln, LN6 4RH

Response Date: 23 February 2023

This report includes the Substantive response of the Local Highway and Lead Local Flood Authority to a planning consultation received under the Development Management Order and includes details of any planning conditions or informatives that should be attached in the event that permission is granted and any obligations to be secured by way of a S106 agreement.

General Information and Advice

Outline applications and contributions

The anticipated number and type of dwellings and/or the floor space may be set by the developer at the time of application which is used to assess necessary mitigation. If not stated in the application, a policy compliant mix will be used. The number and type of dwellings used when assessing S106 planning obligations is set out on the first page of this response.

In the case of outline applications, once the unit mix/floor space is confirmed by reserved matters approval/discharge of condition a matrix (if appropriate) will be applied to establish any increase in contributions payable. A further increase in contributions may result if there is a reserved matters approval changing the unit mix/floor space.

Please note that although the Definitive Map and Statement proves the existence of any recorded rights of way, there may be further or higher rights that are not shown on this document that the County Council is not currently aware of. This would be especially relevant where the public has had informal access to the site or where there are references to routes across this in maps or other historic documents. As the County Council has

received no application to recognise further rights of way affecting the site, no more informed guidance can be offered at this stage.

Application number: 22/1046/FUL

Application Type: Major

Location: 66 Jerusalem Road, Skellingthorpe, Lincoln, LN6 4RH

Highway and Lead Local Flood Authority Report

Substantive Response provided in accordance with article 22(5) of The Town and Country Planning (Development Management Procedure) (England) Order 2015:

Recommendation: Approve with conditions

- **Planning Conditions** as detailed below.

Comments:

This is an Full application for the erection of 28 dwellings & associated external works, formation of access and demolition of no. 66 Jerusalem Road. The development will comprise of 20 x 2 bed and 8 x 3 bed dwellings. There will be a direct connection to the Sustrans route to the north.

Introduction/Site Location

The site is located on Jerusalem Road in Skellingthorpe on the eastbound side of the carriageway.

Existing Conditions

The existing dwelling is to be demolished the the southern boundary hedge removed to provide access to the site.

Highway safety

There are no recorded personal injury accidents in the immediate locale. Jerusalem Road is subject to a 30mph speed limit. Visibility can be achieved in accordance with Manual for Streets. There are connecting footways existing on Jerusalem Road and a range of facilities in walking distance . Bus Stops on Swallow Avenue which is 150m walk.

Highway capacity

28 Dwellings is below the threshold to submit a Transport Assessment - the proposed vehicle movements do not cause any concern for the Village and its capacity.

There is no precise definition of "severe" with regards to NPPF Paragraph 109, which advises that "Development should only be prevented or refused on highways grounds if there would be an unacceptable impact on highway safety, or the residual cumulative impacts on the road

network would be severe." Planning Inspector's decisions regarding severity are specific to the locations of each proposal, but have common considerations:

- The highway network is over-capacity, usually for period extending beyond the peak hours
- The level of provision of alternative transport modes
- Whether the level of queuing on the network causes safety issues

In view of these criteria, the Highways and Lead Local Flood Authority does not consider that this proposal would result in a severe impact with regard to NPPF.

Site Layout

Delivery/Refuse vehicles will reverse into the spur roads so they can leave in a forward gear. Concerns were raised over the tactile crossing that would be installed at the site access and plots 1 would have to drive over them to access their parking spaces, the Planner said this could not be changed due to the build line therefore a Commuted sum will be applied at Section 38 Stage to cover the maintenance/repair of the tactiles.

Flood Risk and Drainage

Infiltration is acceptable in principle subject to further testing. They propose to raise floor levels 150mm above ground level due to the presence of ground water – the existing site falls from SW to NE, the same for proposed levels (NE being raised making the site flat). Surface Water flood maps do not show a flood route going through the site. Type 3 material will be used to provide better permeability/storage characteristics.

Drainage proposal includes Check Dams – commuted sum to be applied at Section 38 stage.

Off-Site Improvements

As the 28 dwelling development will increase footfall on Jerusalem Road to provide better connectivity it has been conditioned that a series of Tactile Crossing points are to be installed along the route to the nearest facilities.

Planning Conditions:

In the event that permission is to be given, the following planning conditions should be attached:

Highway Condition 21

No part of the development hereby permitted shall be occupied before the works to improve the public highway (by means of installing 5no. pedestrian Tactile Crossing points at the site access, Moss Lane, Old Chapel Road, The Hill & The Co-Op have been certified complete by the Local Planning Authority.

To ensure the provision of safe and adequate means of access to the permitted development.

Highway Condition 00

The development hereby permitted shall be undertaken in accordance with a Construction Management Plan and Method Statement that shall first be approved in writing by the Local Planning Authority. The Plan and Statement shall indicate measures to mitigate the adverse impacts of vehicle activity and the means to manage the drainage of the site during the construction stage of the permitted development. It shall include;

- the phasing of the development to include access construction;
- the on-site parking of all vehicles of site operatives and visitors;
- the on-site loading and unloading of all plant and materials;
- the on-site storage of all plant and materials used in constructing the development;
- wheel washing facilities;
- the routes of construction traffic to and from the site including any off-site routes for the disposal of excavated material and;
- strategy stating how surface water run off on and from the development will be managed during construction and protection measures for any sustainable drainage features. This should include drawing(s) showing how the drainage systems (temporary or permanent) connect to an outfall (temporary or permanent) during construction.

Reason: In the interests of the safety and free passage of those using the adjacent public highway and to ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, the permitted development during construction.

Highway Condition 26

Before any dwelling is occupied, all of that part of the estate road and associated footways that forms the junction with the main road and which will be constructed within the limits of the existing highway, shall be laid out and constructed to finished surface levels in accordance with details to be submitted to, and approved in writing by, the Local Planning Authority.

Reason: In the interests of safety, to avoid the creation of pedestrian trip hazards within the public highway from surfacing materials, manholes and gullies that may otherwise remain for an extended period at dissimilar, interim construction levels.

Highway Condition 29

The permitted development shall be undertaken in accordance with an Estate Road Phasing and Completion Plan, which shall first be approved in writing by the Local Planning Authority. The Plan shall set out how the construction of the development will be phased and standards to which the estate roads on each phase will be completed during the construction period of the development.

Reason: To ensure that a safe and suitable standard of vehicular and pedestrian access is provided for residents throughout the construction period of the development.

Highway Condition 33

The permitted development shall be undertaken in accordance with a surface water drainage scheme which shall first have been approved in writing by the Local Planning Authority.

The scheme shall:

- be based on sustainable drainage principles and an assessment of the hydrological and hydrogeological context of the development;
- provide flood exceedance routing for storm event greater than 1 in 100 year;
- provide details of how run-off will be safely conveyed and attenuated during storms up to and including the 1 in 100 year critical storm event, with an allowance for climate change, from all hard surfaced areas within the development into the existing local drainage infrastructure and watercourse system without exceeding the run-off rate for the undeveloped site;
- provide attenuation details and discharge rates which shall be restricted to Greenfield run off rate;
- provide details of the timetable for and any phasing of implementation for the drainage scheme; and
- provide details of how the scheme shall be maintained and managed over the lifetime of the development, including any arrangements for adoption by any public body or Statutory Undertaker and any other arrangements required to secure the operation of the drainage system throughout its lifetime.

No dwelling/ no part of the development shall be occupied until the approved scheme has been completed or provided on the site in accordance with the approved phasing. The approved scheme shall be retained and maintained in full, in accordance with the approved details.

Reason: To ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, or upstream of, the permitted development.

Informatives

Highway Informative 07

The highway improvement works referred to in the above condition are required to be carried out by means of a legal agreement between the landowner and the County Council, as the Local Highway Authority.

For further guidance please visit our website;
www.lincolnshire.gov.uk/highways-planning/works-existing-highway

Highway Informative 03

The permitted development requires the formation of a new/amended vehicular access. These works will require approval from the Highway Authority in accordance with Section 184 of the Highways Act. Any traffic management required to undertake works within the highway will be subject to agreement. The access must be constructed in accordance with a current specification issued by the Highway Authority. Any requirement to relocate existing apparatus, underground services, or street furniture because of the installation of an access will be the responsibility, and cost, of the applicant and must be agreed prior to a vehicle access application. The application form, costs and guidance documentation can be found on our website, accessible via the following link:
<https://www.lincolnshire.gov.uk/licences-permits/apply-dropped-kerb>.

Highway Informative 08

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections, Section 50 licences and any other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works. For further guidance please visit our website via the following link: Traffic Management -
<https://www.lincolnshire.gov.uk/traffic-management>

Highway Informative 09

The existing ground level of the site must not be raised above the ground level of any surrounding land without further consultation with the Lead Local Flood Authority and Local Planning Authority, to consider suitable mitigation measures to ensure that surface water flood risk is not created or increased to land adjacent to the permitted development.

Highway Informative 05

All roads within the development hereby permitted must be constructed to an acceptable engineering standard. Those roads that are to be put forward for adoption as public highways must be constructed in accordance with the Lincolnshire County Council Development Road Specification that is current at the time of construction and the developer will be required to enter into a legal agreement with the Highway Authority under Section 38 of the Highways Act 1980. Those roads that are not to be voluntarily put forward for adoption as public highways, may be subject to action by the Highway Authority under Section 219 (the Advance Payments code) of the Highways Act 1980. For guidance, please refer to
<https://www.lincolnshire.gov.uk>

Officer's Name: Sam Wood

Officer's Title: Senior Development Management Officer

Date: 23 February 2023