

LINCOLNSHIRE COUNTY COUNCIL'S RESPONSE TO CONSULTATION ON THE FOLLOWING DEVELOPMENT PROPOSAL

District: Boston Borough Council

Application number: B/23/0419

Application Type: Full-Major

Proposal: Erection of coldstore

Location: Marsh Farm, Sea Lane, Wrangle, Boston, PE22 9HE

Response Date: 18 December 2023

This report includes the Substantive response of the Local Highway and Lead Local Flood Authority to a planning consultation received under the Development Management Order and includes details of any planning conditions or informatives that should be attached in the event that permission is granted and any obligations to be secured by way of a S106 agreement.

General Information and Advice

Please note that although the Definitive Map and Statement proves the existence of any recorded rights of way, there may be further or higher rights that are not shown on this document that the County Council is not currently aware of. This would be especially relevant where the public has had informal access to the site or where there are references to routes across this in maps or other historic documents. As the County Council has received no application to recognise further rights of way affecting the site, no more informed guidance can be offered at this stage.

Application number: B/23/0419

Application Type: Full-Major

Location: Marsh Farm, Sea Lane, Wrangle, Boston, PE22 9HE

Highway and Lead Local Flood Authority Report

Substantive Response provided in accordance with article 22(5) of The Town and Country Planning (Development Management Procedure) (England) Order 2015:

Recommendation: No objection

This proposal is for the erection of a cold store and the access and parking arrangements remain unchanged; therefore, it is considered that the proposals would not result in an unacceptable impact on highway safety.

There is adequate parking and turning facility within the site for agricultural machinery and HGV's which will not be impeded by this proposal.

As Lead Local Flood Authority, Lincolnshire County Council is required to provide a statutory planning consultation response with regard to Drainage on all Major Applications. This application (expand as appropriate). Therefore the Lead Local Flood Authority does not consider that this proposal would increase flood risk in the immediate vicinity of the site. The roof water from the building will be connected and stored on site to the existing lagoon, therefore there will be no increase in surface water run-off.

No Objections

Having given due regard to the appropriate local and national planning policy guidance (in particular the National Planning Policy Framework), Lincolnshire County Council (as Highway Authority and Lead Local Flood Authority) has concluded that the proposed development would not be expected to have an unacceptable impact upon highway safety or a severe residual cumulative impact upon the local highway network or increase surface water flood risk and therefore does not wish to object to this planning application.

Officer's Name: Dean Whitehead

Officer's Title: Senior Development Management Officer

Date: 18 December 2023



Lincolnshire
FIRE & RESCUE

Fire and Police Headquarters
Deepdale Lane
Nettleham
Lincoln
LN2 2LT
Tel: 01522 555777
www.lincolnshire.gov.uk/lfr

My Ref: 200004476503/JF
Your Ref: B/23/0419

Head of Planning
Lincolnshire County Council
County Offices
Newland
Lincoln
LN1 1YL

For the attention of Ian Carrington

Sent by email to HighwaysSUDsSupport@lincolnshire.gov.uk

8 December 2023

Dear Sir

TOWN AND COUNTRY PLANNING ACT 1990

PLANNING CONSULTATION: ERECTION OF COLDSTORE

LOCATION: MARSH FARM, SEA LANE, WRANGLE, BOSTON, PE22 9HE

I refer to the planning application reference B/23/0419. The Fire Authority object to the application on the grounds of inadequate access and water supply. It is the opinion of the Fire Authority that in order to remove the objection the following measures are required.

Access to buildings for fire appliances and fire fighters must meet with the requirements specified in Building Regulations 2010 Part B5. These requirements may be satisfied with other equivalent standards relating to access for fire fighting, in which case those standards should be quoted in correspondence.

Lincolnshire Fire and Rescue also requires a minimum carrying capacity for hard standing for pumping appliances of 18 tonnes, not 12.5 tonnes as detailed in the Building Regulations 2010 part B5. This weight limit would also apply to any private/shared access roads in order to achieve the above item.

Lincolnshire Fire and Rescue requires the installation of one fire hydrant conforming to BS750-2012 within 90m of the premises entrance in respect of this planning application to be provided at the developer's expense. Fire hydrant acceptance testing will be carried out by a Hydrant Inspector on completion and a standard hydrant marker "H" plate will be fitted

nearby. Following adoption the Fire Service will be responsible for the ongoing maintenance and repairs for the lifetime of the fire hydrant.

Should you wish to discuss this matter, please do not hesitate to contact me on the telephone number below.

Yours faithfully

Joshua Frost
Fire Safety Inspector
Email: fire.safety@lincolnshire.gov.uk
Tel : 01522 553868

CC : LFR Water Officer