

LINCOLNSHIRE COUNTY COUNCIL'S RESPONSE TO CONSULTATION ON THE FOLLOWING DEVELOPMENT PROPOSAL

District: East Lindsey District Council

Application number: N/003/01464/23

Application Type: Outline – Major Planning Application

Proposal: Outline erection of 14no. dwellings

Location: Land off Farlesthorne Road, Alford

Response Date: 6 December 2023

This report includes the Substantive response of the Local Highway and Lead Local Flood Authority to a planning consultation received under the Development Management Order and includes details of any planning conditions or informatives that should be attached in the event that permission is granted and any obligations to be secured by way of a S106 agreement.

General Information and Advice

Please note that although the Definitive Map and Statement proves the existence of any recorded rights of way, there may be further or higher rights that are not shown on this document that the County Council is not currently aware of. This would be especially relevant where the public has had informal access to the site or where there are references to routes across this in maps or other historic documents. As the County Council has received no application to recognise further rights of way affecting the site, no more informed guidance can be offered at this stage.

Outline applications and contributions

The anticipated number and type of dwellings and/or the floor space may be set by the developer at the time of application which is used to assess necessary mitigation. If not stated in the application, a policy compliant mix will be used. The number and type of dwellings used when assessing S106 planning obligations is set out on the first page of this response.

In the case of outline applications, once the unit mix/floor space is confirmed by reserved matters approval/discharge of condition a matrix (if appropriate) will be applied to establish any increase in contributions payable. A further increase in contributions may result if there is a reserved matters approval changing the unit mix/floor space.

Application number: N/003/01464/23

Application Type: Outline – Major Planning Application

Location: Land off Farlesthorne Road, Alford

Highway and Lead Local Flood Authority Report

Substantive Response provided in accordance with article 22(5) of The Town and Country Planning (Development Management Procedure) (England) Order 2015:

Recommendation: No objection subject to:

- **Construction Management Plan**
- **Crossing point**
- **Tactile crossing upgrades**
- **Safe level of infrastructure**
- **Drainage detail**

Comments:

The site is located to the Southeast of Alford and follows on a line of previous development. Farlesthorne Road is of mixed used, however, the majority of the Road is used for residential dwellings. There is a large amount of agricultural vehicles and lorries that use the road, in school times it is often used for drop off and pick up of school children.

The outline proposal that has been put forward is for 14 dwellings and the principle of development is acceptable. As this is an outline application with all matters reserved, access and layout have not been considered. Please make the applicant aware of the requirements for access, parking, visibility, turning and layout as detailed within the Lincolnshire County Council Design Approach.

However, the applicant has provided an indicative site plan sent on the 17th of November 2023, therefore, the Highway Authority would wish to advise the applicant at this early stage of our comments in order to support any further application. The access road to service the proposed development is of a similar nature and in keeping with others along Farlesthorne Road and in principle would seem to be acceptable and the road layout could accommodate a refuge vehicle to carry out collections including turning within the site. The applicant has taken on board the comments referring to tree lined streets and incorporated these into the layout. A link footpath has been provided to the southeast of the site to promote a sustainable pedestrian route to the East of the site.

Due to the close proximity of local schools, Farlesthorne Road sees a large increase of on street parking and the passage of school children during school drop off and pick up times. I would recommend that the Local Planning Authority consider a condition to restrict deliveries during these times, I would also expect to see delivery times restricted in the Construction Management Plan.

Flood Risk and Drainage

As Lead Local Flood Authority, Lincolnshire County Council is required to provide a statutory planning consultation response with regard to Drainage on all Major Applications. This application it is proposed that surface water will be captured by the use of swales, which will then convey the surface water into attenuation basin, from there the flow will be controlled as the surface water is discharged into an IDB drain. Therefore the Lead Local Flood Authority does not consider that this proposal would increase flood risk in the immediate vicinity of the site.

Planning Conditions:

In the event that permission is to be given, the following planning conditions should be attached:

Highway Condition 00

The development hereby permitted shall be undertaken in accordance with a Construction Management Plan and Method Statement that shall first be approved in writing by the Local Planning Authority. The Plan and Statement shall indicate measures to mitigate the adverse impacts of vehicle activity and the means to manage the drainage of the site during the construction stage of the permitted development. It shall include;

- the phasing of the development to include access construction;
- the on-site parking of all vehicles of site operatives and visitors;
- the on-site loading and unloading of all plant and materials;
- the on-site storage of all plant and materials used in constructing the development;
- wheel washing facilities;
- the routes of construction traffic to and from the site including any off-site routes for the disposal of excavated material and;
- restricted delivery times outside of school drop off and pick up;
- strategy stating how surface water run off on and from the development will be managed during construction and protection measures for any sustainable drainage features. This should include drawing(s) showing how the drainage systems (temporary or permanent) connect to an outfall (temporary or permanent) during construction.

Reason: In the interests of the safety and free passage of those using the adjacent public highway and to ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, the permitted development during construction.

Highway Condition 20.1

The development hereby permitted shall not be occupied before a tactile crossing point is installed on Farlesthorpe Road, to allow safe passage from the development to the link footpath to Hanby Lane, has been provided in accordance with details that shall first have been submitted to, and approved in writing by, the Local Planning Authority. The works shall also include appropriate arrangements for the management of surface water run-off from the highway.

Reason: To ensure the provision of safe and adequate pedestrian crossing point to the permitted development, without increasing flood risk to the highway and adjacent land and property.

Highway Condition 20.2

The development hereby permitted shall not be occupied before the 7 crossing points along Farlesthorne Road are upgraded to tactile crossing points. To avoid any doubt, these crossing points fall at the following locations; Rawnsley Close junction, Gibson Way junction, Industrial units access, Conlie Close junction, both Children's Centre accesses and across the Farlesthorne Road at the junction with South Street.

Reason: To ensure the provision of safe and adequate pedestrian access from the permitted development to local facilities.

Highway Condition 26

Before any dwelling is occupied, all of that part of the estate road and associated footways that forms the junction with the main road and which will be constructed within the limits of the existing highway, shall be laid out and constructed to finished surface levels in accordance with details to be submitted to, and approved in writing by, the Local Planning Authority.

Reason: In the interests of safety, to avoid the creation of pedestrian trip hazards within the public highway from surfacing materials, manholes and gullies that may otherwise remain for an extended period at dissimilar, interim construction levels.

Highway Condition 33

The permitted development shall be undertaken in accordance with a surface water drainage scheme which shall first have been approved in writing by the Local Planning Authority.

The scheme shall:

- be based on sustainable drainage principles and an assessment of the hydrological and hydrogeological context of the development;
- provide flood exceedance routing for storm event greater than 1 in 100 year;
- provide details of how run-off will be safely conveyed and attenuated during storms up to and including the 1 in 100 year critical storm event, with an allowance for climate change, from all hard surfaced areas within the development into the existing local drainage infrastructure and watercourse system without exceeding the run-off rate for the undeveloped site;
- provide attenuation details and discharge rates which shall be restricted to 5.7 litres per second;
- provide details of the timetable for and any phasing of implementation for the drainage scheme; and
- provide details of how the scheme shall be maintained and managed over the lifetime of the development, including any arrangements for adoption by any public body or Statutory Undertaker and any other arrangements required to secure the operation of the drainage system throughout its lifetime.

No dwelling/ no part of the development shall be occupied until the approved scheme has been completed or provided on the site in accordance with the approved phasing. The approved scheme shall be retained and maintained in full, in accordance with the approved details.

Reason: To ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, or upstream of, the permitted development.

Informatives

Highway Informative 03

The permitted development requires the formation of a new/amended vehicular access. These works will require approval from the Highway Authority in accordance with Section 184 of the Highways Act. Any traffic management required to undertake works within the highway will be subject to agreement. The access must be constructed in accordance with a current specification issued by the Highway Authority. Any requirement to relocate existing apparatus, underground services, or street furniture because of the installation of an access will be the responsibility, and cost, of the applicant and must be agreed prior to a vehicle access application. The application form, costs and guidance documentation can be found on the Highway Authority's website, accessible via the following link:
<https://www.lincolnshire.gov.uk/licences-permits/apply-dropped-kerb>.

Highway Informative 05

All roads within the development hereby permitted must be constructed to an acceptable engineering standard. Those roads that are to be put forward for adoption as public highways must be constructed in accordance with the Lincolnshire County Council Development Road Specification that is current at the time of construction and the developer will be required to enter into a legal agreement with the Highway Authority under Section 38 of the Highways Act 1980. Those roads that are not to be voluntarily put forward for adoption as public highways, may be subject to action by the Highway Authority under Section 219 (the Advance Payments code) of the Highways Act 1980. For guidance, please refer to
<https://www.lincolnshire.gov.uk>

Highway Informative 07

The highway improvement works referred to in the above condition are required to be carried out by means of a legal agreement between the landowner and the County Council, as the Local Highway Authority.

For further guidance please visit our website;
www.lincolnshire.gov.uk/highways-planning/works-existing-highway

Highway Informative 08

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections, Section 50 licences and any

other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works. For further guidance please visit the Highway Authority's website via the following link: Traffic Management - <https://www.lincolnshire.gov.uk/traffic-management>

Officer's Name: Joseph Walden

Officer's Title: Senior Development Management Officer

Date: 6 December 2023

East Lindsey District Council
Development Control
Planning Department

Corporate Property Team
Lincolnshire County Council
County Offices
Newland
Lincoln LN1 1YL

Email: Property_Strategy@Lincolnshire.gov.uk

My Ref: S106/ELDC/N/003/01464/23
03 August 2023

Dear Sir/Madam

Development – OUTLINE ERECTION OF 14NO. DWELLINGS
LAND OFF FARLESTHORPE ROAD, ALFORD
Application Number – N/003/01464/23

Thank you for your notification of 02 August 2023, concerning the proposed development at the above site. I have now had the opportunity to consider the impact on the local schools reasonably accessible from the development. Please see below overview in relation to the impact, and details for primary, secondary and sixth-form that follow.

Overview

Please see below table in relation to the number of places required and available in local schools from/for the proposed development:

Type	Children produced by scheme	Sufficient places available 2025/26 (Y/N/Partial)	Places to be mitigated	Contribution sought
Primary	2	Y	0	£ 0
Secondary	2	N	2	£ 51,006
Sixth-form	0	N/A	0	£ 0
			Total	£ 51,006

Please note, where an application is outline a formulaic approach will be taken in a section 106 agreement, this may result in a higher contribution if a high proportion of large houses are built. This would be finalised at the reserved matters stage. All section 106 agreements should include indexation using the Tender Price Index of the Royal Institute of Chartered Surveyors Building Cost Information Services (RICS BCIS TPI).

The above contributions would be spent on the following:

Type	Amount	Scheme
Primary	£ 0	
Secondary	£ 51,006	Education provision in Alford Secondary planning area
Sixth-form	£ 0	

Following the removal of Regulation 123 from the Community Infrastructure Levy Regulations on 01 September 2019, requests can be made toward more than one scheme to provide the ability to extend the most appropriate school to mitigate the impacts of development at the time those impacts are felt.

Detail

The below table indicates the number of pupils generated by the proposed development. This is on the basis of research by Lincolnshire Research Observatory utilised to calculate Pupil Production Ratio (PPR) multiplied by the number of homes proposed.

House Type (if known)	No of Properties	PPR Primary	Primary Pupils	PPR Secondary	Secondary Pupils	PPR Sixth Form	Sixth Form Pupils
Unknown	14	0.2	2.8	0.19	2.66	0.038	0.532
Total (rounded down)	14	-	2	-	2	-	0

Capacity is assessed using the County Council's projected capacity levels at 2025/26, this is the point when it is reasonable to presume that the development would be complete or well on the way.

Type	Local School/School Planning Area	Pupils generated	Sufficient places available 2025/26 (Y/N/Partial)	Places to be mitigated
Primary	Alford Primary planning area	2	Y	0
Secondary	Alford Secondary planning area	2	N	2
Sixth-form	Alford Secondary planning area	0	N/A	0

As the development would result in a direct impact on local schools, a contribution is therefore requested to mitigate the impact of the development at local level. This is a recognisable and legitimate means of addressing an impact on infrastructure, accords with the NPPF (2019) and fully complies with CIL regulations; we feel it is necessary, directly related, and fairly and reasonably related in scale and kind to the development proposed in this application.

The level of contribution sought in this case is in line with the below table.

Type	Places to be mitigated	Contribution per place*	Sub-total	Local multiplier**	Lincolnshire contribution per place	Total contribution requested
Secondary extension	2	£25,003	£50,006	2.00	£25,503	£51,006
Total	-	-	£50,006	-		£51,006

* Current cost multiplier per pupil place based on National Cost Survey

** to reflect Lincolnshire's average build cost compared to national average

We would suggest the s.106 monies are paid at the halfway point in the development to allow timely investment by the County Council whilst not adversely affecting the developer's viability.

Please note the County Council retains the statutory duty to ensure sufficiency of school places and this includes capital funding provision of sufficient places at maintained schools, academies and free schools. We would invest the funding at the most appropriate local school(s) regardless of their status, but ensure the s.106 funding is used only to add capacity as this is the only purpose for which it is requested.

I look forward to hearing from you, thank you for your notification of the application and thank East Lindsey District Council for your continued cooperation and support.

Yours sincerely

Sam Barlow
Strategic Development Officer
Corporate Property Service

(By e-mail)