

LINCOLNSHIRE COUNTY COUNCIL'S RESPONSE TO CONSULTATION ON THE FOLLOWING DEVELOPMENT PROPOSAL

District: Lincolnshire County Council

Application number: PL/0059/23

Application Type: Major

Proposal: For construction of a building to be used as a transfer and bulking station for recycled materials alongside land reclamation to create development platform

Location: Land at Leafbridge, Station Road, North Hykeham

Response Date: 6 December 2023

This report includes the Substantive response of the Local Highway and Lead Local Flood Authority to a planning consultation received under the Development Management Order and includes details of any planning conditions or informatives that should be attached in the event that permission is granted and any obligations to be secured by way of a S106 agreement.

General Information and Advice

Please note that although the Definitive Map and Statement proves the existence of any recorded rights of way, there may be further or higher rights that are not shown on this document that the County Council is not currently aware of. This would be especially relevant where the public has had informal access to the site or where there are references to routes across this in maps or other historic documents. As the County Council has received no application to recognise further rights of way affecting the site, no more informed guidance can be offered at this stage.

Application number: PL/0059/23

Application Type: Major

Location: Land at Leafbridge, Station Road, North Hykeham

Highway and Lead Local Flood Authority Report

Substantive Response provided in accordance with article 22(5) of The Town and Country Planning (Development Management Procedure) (England) Order 2015:

Recommendation:

No objection subject to Planning Conditions as detailed below.

Introduction/Site Location

The proposals are the construction of a Waste Transfer Station on a development plot, currently used to store aggregates, within the wider Leafbridge development . The proposals include the infilling of existing pond off Station Road, North Hykeham

Highway safety

The Highways and Lead Local Flood Authority response is in relation to the impact the proposed development would be expected to have on the operation of the Public Highway. Leafbridge Way is a private road, and the highway authority has no jurisdiction over the use of this road. With regard to this application, we have considered the safety and impact of these proposals on Adopted Road Station Road and its junction with Leafbridge Way. It is for the Local Planning Authority to determine whether the access provided by the private road is safe and suitable for all users.

Highway capacity

There is no precise definition of "severe" with regards to NPPF Paragraph 111, which advises that "Development should only be prevented or refused on highways grounds if there would be an unacceptable impact on highway safety, or the residual cumulative impacts on the road network would be severe." Planning Inspector's decisions regarding severity are specific to the locations of each proposal, but have common considerations:

- The highway network is over-capacity, usually for period extending beyond the peak hours
- The level of provision of alternative transport modes
- Whether the level of queuing on the network causes safety issues

In view of these criteria, the Highways and Lead Local Flood Authority does not consider that this proposal would result in a severe impact with regard to NPPF.

Flood Risk and Drainage

As Lead Local Flood Authority, Lincolnshire County Council is required to provide a statutory planning consultation response with regard to Drainage on all Major Applications. This application proposes to construct a channel along the North of the development and will ensure conditions upstream of the ponds to be in filled remains as existing. To provide an

attenuation basin with sufficient capacity with a flow control device to limit discharge to greenfield rate with the final outfall into Pike Drain which will require consent from the IDB, the site is located in Flood Zone 1 . Therefore the Lead Local Flood Authority does not consider that this proposal would increase flood risk in the immediate vicinity of the site.

Planning Conditions:

In the event that permission is to be given, the following planning conditions should be attached:

Highway Condition 21

No part of the development hereby permitted shall be occupied before the works to improve the public highway by a ghost island right turn off Station Road, North Hykeham have been certified complete by the Local Planning Authority.

Reason: To ensure the provision of safe and adequate means of access to the permitted development.

Highway Condition 33

The permitted development shall be undertaken in accordance with a surface water drainage scheme which shall first have been approved in writing by the Local Planning Authority.

The scheme shall:

- be based on sustainable drainage principles and an assessment of the hydrological and hydrogeological context of the development;
- provide flood exceedance routing for storm event greater than 1 in 100 year;
- provide details of how run-off will be safely conveyed and attenuated during storms up to and including the 1 in 100 year critical storm event, with an allowance for climate change, from all hard surfaced areas within the development into the existing local drainage infrastructure and watercourse system without exceeding the run-off rate for the undeveloped site;
- provide attenuation details and discharge rates which shall be restricted to Greenfield rate;
- provide details of the timetable for and any phasing of implementation for the drainage scheme; and
- provide details of how the scheme shall be maintained and managed over the lifetime of the development, including any arrangements for adoption by any public body or Statutory Undertaker and any other arrangements required to secure the operation of the drainage system throughout its lifetime.

No part of the development shall be occupied until the approved scheme has been completed. The approved scheme shall be retained and maintained in full, in accordance with the approved details.

Reason: To ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, or upstream of, the permitted development.

Informatives

Highway Informative 04

The road serving the permitted development is approved as a private road which will not be adopted as a Highway Maintainable at the Public Expense (under the Highways Act 1980). As such, the liability for the future maintenance of the road will rest with those who gain access to their property from it.

Highway Informative 07

The highway improvement works referred to in the above condition are required to be carried out by means of a legal agreement between the landowner and the County Council, as the Local Highway Authority.

For further guidance please visit our website;
www.lincolnshire.gov.uk/highways-planning/works-existing-highway

Officer's Name: Helen Patchett

Officer's Title: Senior Development Management Officer

Date: 6 December 2023