

LINCOLNSHIRE COUNTY COUNCIL'S RESPONSE TO CONSULTATION ON THE FOLLOWING DEVELOPMENT PROPOSAL

District: East Lindsey District Council

Application number: N/085/01107/23

Application Type: Reserved Matters - Major

Proposal: Reserved Matters application relating to the erection of 48no. dwellings with associated garages, play equipment, attenuation pond, landscaping and internal access roads in relation to application N/085/01207/20

Location: Land east of Louth Road, Holton le Clay

Response Date: 1 November 2023

This report includes the Substantive response of the Local Highway and Lead Local Flood Authority to a planning consultation received under the Development Management Order and includes details of any planning conditions or informatives that should be attached in the event that permission is granted and any obligations to be secured by way of a S106 agreement.

General Information and Advice

Please note that although the Definitive Map and Statement proves the existence of any recorded rights of way, there may be further or higher rights that are not shown on this document that the County Council is not currently aware of. This would be especially relevant where the public has had informal access to the site or where there are references to routes across this in maps or other historic documents. As the County Council has received no application to recognise further rights of way affecting the site, no more informed guidance can be offered at this stage.

Application number: N/085/01107/23
Application Type: Reserved Matters - Major
Location: Land east of Louth Road, Holton le Clay

Highway and Lead Local Flood Authority Report

Substantive Response provided in accordance with article 22(5) of The Town and Country Planning (Development Management Procedure) (England) Order 2015:

Recommendation: Approve with Conditions

Comments:

This is a reserved matters application for 48 dwellings, following outline permission granted under reference N/085/00883/15 and N/085/01207/20 for the erection of up to 300 dwellings. This site is the northernmost portion of the land to be developed under the outline permission, referenced in the masterplan as Phase A.

Vehicular access to the site is gained from Louth Road. Pedestrian and cycling connections are to be made to Louth Road and into the wider residential development to the south.

Streets within the development are proposed to be adopted to be maintained at public expense. Where private drives are proposed, bin collection points will be provided to assist with refuse collection. Streets throughout the development will have trees planted in highway verges, in keeping with the proposed street scene of the rest of the development site.

A leisure circular footway around the site perimeter is proposed, however this is not proposed for adoption as highway. A connection will be made at the north-west corner of the site between this route and Clay Lane.

Surface water will be collected from streets by gullies and pipes, attenuated in a basin to east of the site (maintained by a private management company) before discharging at a restricted rate to the boundary ditch to the east. This is in accordance with the drainage strategy approved at outline stage. Swales are not viable for delivery on this site due to the high groundwater table.

Planning Conditions:

Highway Condition 00

The development hereby permitted shall be undertaken in accordance with a Construction Management Plan and Method Statement that shall first be approved in writing by the Local Planning Authority. The Plan and Statement shall indicate measures to mitigate the adverse impacts of vehicle activity and the means to manage the drainage of the site during the construction stage of the permitted development. It shall include;

- the phasing of the development to include access construction;
- the on-site parking of all vehicles of site operatives and visitors;
- the on-site loading and unloading of all plant and materials;
- the on-site storage of all plant and materials used in constructing the development;

- wheel washing facilities;
- the routes of construction traffic to and from the site including any off-site routes for the disposal of excavated material and;
- strategy stating how surface water run off on and from the development will be managed during construction and protection measures for any sustainable drainage features. This should include drawing(s) showing how the drainage systems (temporary or permanent) connect to an outfall (temporary or permanent) during construction.

Reason: In the interests of the safety and free passage of those using the adjacent public highway and to ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, the permitted development during construction.

Highway Condition 33

The permitted development shall be undertaken in accordance with a surface water drainage scheme which shall first have been approved in writing by the Local Planning Authority.

The scheme shall:

- be based on sustainable drainage principles and an assessment of the hydrological and hydrogeological context of the development;
- provide flood exceedance routing for storm event greater than 1 in 100 year;
- provide details of how run-off will be safely conveyed and attenuated during storms up to and including the 1 in 100 year critical storm event, with an allowance for climate change, from all hard surfaced areas within the development into the existing local drainage infrastructure and watercourse system without exceeding the run-off rate for the undeveloped site;
- provide attenuation details and discharge rates which shall be restricted to XXX litres per second;
- provide details of the timetable for and any phasing of implementation for the drainage scheme; and
- provide details of how the scheme shall be maintained and managed over the lifetime of the development, including any arrangements for adoption by any public body or Statutory Undertaker and any other arrangements required to secure the operation of the drainage system throughout its lifetime.

No dwelling/ no part of the development shall be occupied until the approved scheme has been completed or provided on the site in accordance with the approved phasing. The approved scheme shall be retained and maintained in full, in accordance with the approved details.

Reason: To ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, or upstream of, the permitted development.

Informatives

Highway Informative 02

In accordance with Section 59 of the Highways Act 1980, please be considerate of causing damage to the existing highway during construction and implement mitigation measures as necessary. Should extraordinary expenses be incurred by the Highway Authority in maintaining the highway by reason of damage caused by construction traffic, the Highway Authority may seek to recover these expenses from the developer.

Highway Informative 05

All roads within the development hereby permitted must be constructed to an acceptable engineering standard. Those roads that are to be put forward for adoption as public highways must be constructed in accordance with the Lincolnshire County Council Development Road Specification that is current at the time of construction and the developer will be required to enter into a legal agreement with the Highway Authority under Section 38 of the Highways Act 1980. Those roads that are not to be voluntarily put forward for adoption as public highways, may be subject to action by the Highway Authority under Section 219 (the Advance Payments code) of the Highways Act 1980. For guidance, please refer to <https://www.lincolnshire.gov.uk>

Highway Informative 08

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections, Section 50 licences and any other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works. For further guidance please visit the Highway Authority's website via the following link: Traffic Management - <https://www.lincolnshire.gov.uk/traffic-management>

Officer's Name: Becky Phillips-Melhuish

Officer's Title: Growth Manager (Planning Advice)

Date: 14 November 2023