

LINCOLNSHIRE COUNTY COUNCIL'S RESPONSE TO CONSULTATION ON THE FOLLOWING DEVELOPMENT PROPOSAL

District: East Lindsey District Council

Application number: S/094/00132/24

Application Type: FULL

Proposal: Planning Permission - Erection of a detached dwelling with detached car port, 3no. detached holiday lodges, excavation of land to form 2no. ponds and provision of associated access and car parking

Location: Deans Farm, Kirkby Lane, Kirkby on Bain, LN10 6YZ

Response Date: 27 March 2024

This report includes the Substantive response of the Local Highway and Lead Local Flood Authority to a planning consultation received under the Development Management Order and includes details of any planning conditions or informatives that should be attached in the event that permission is granted and any obligations to be secured by way of a S106 agreement.

General Information and Advice

Please note that although the Definitive Map and Statement proves the existence of any recorded rights of way, there may be further or higher rights that are not shown on this document that the County Council is not currently aware of. This would be especially relevant where the public has had informal access to the site or where there are references to routes across this in maps or other historic documents. As the County Council has received no application to recognise further rights of way affecting the site, no more informed guidance can be offered at this stage.

Application number: S/094/00132/24

Application Type: FULL

Location: Deans Farm, Kirkby Lane, Kirkby on Bain, LN10 6YZ

Highway and Lead Local Flood Authority Report

Substantive Response provided in accordance with article 22(5) of The Town and Country Planning (Development Management Procedure) (England) Order 2015:

Recommendation: No Objections subject to planning conditions listed below

Having given due regard to the appropriate local and national planning policy guidance (in particular the National Planning Policy Framework), Lincolnshire County Council (as Highway Authority and Lead Local Flood Authority) has concluded that the proposed development would not be expected to have an unacceptable impact upon highway safety or a severe residual cumulative impact upon the local highway network or increase surface water flood risk and therefore does not wish to object to this planning application.

Comments:

The site is situated to the south of Kirkby Lane and is approximately 2.0 hectares. It includes poultry sheds and corn silos. There is an existing rainwater drainage system leading to a soakaway.

Historical data indicates two "slight" accidents within the past five years, neither of which were attributed to the site access. The access point meets the national speed limit highway, and the road's bends naturally moderate traffic speed, thereby reducing risk.

The visibility at the access is 43m which complies with Manual for Streets (MfS). Kirkby Lane has a speed limit of 60mph and is a C road, but due to factors including alignment of the road and driver behaviour; visibility in accordance with MfS is deemed appropriate rather than visibility set out in DMRB which are Department for Transport standards for Trunk Roads. The dimensions of the proposed access are adequate to enable 2 cars to pass in opposing directions and the proposal would therefore not result in an unacceptable impact on highway safety.

While residents have expressed concerns regarding increased traffic, the site already has permission for use as a poultry farm and this will generate a comparable amount of trips. It is therefore not possible to raise an objection to the proposals based on traffic impact, in accordance with the NPPF.

As Highways and Lead Local Flood Authority It is our role in the planning process to ensure that any proposed development does not adversely impact on the current network, should the drainage proposals result in not making worse the current situation, it would not be possible to recommend refusal or raise an objection. The drainage strategy includes the implementation of swales and a pond to manage surface water flooding. The pond will serve as a retention basin, enhancing water attenuation before ground infiltration. A flood routing plan has been submitted to further address this concern. The surface water runoff is directed into a catchwater drain located northwest of the site.

Planning Conditions:

In the event that permission is to be given, the following planning conditions should be attached:

Highway Condition 33

The permitted development shall be undertaken in accordance with a surface water drainage scheme which shall first have been approved in writing by the Local Planning Authority.

The scheme shall:

- be based on sustainable drainage principles and an assessment of the hydrological and hydrogeological context of the development;
- provide flood exceedance routing for storm event greater than 1 in 100 year;
- provide details of how run-off will be safely conveyed and attenuated during storms up to and including the 1 in 100 year critical storm event, with an allowance for climate change, from all hard surfaced areas within the development into the existing local drainage infrastructure and watercourse system without exceeding the run-off rate for the undeveloped site;
- provide attenuation details and discharge rates which shall be restricted to XXX litres per second;
- provide details of the timetable for and any phasing of implementation for the drainage scheme; and
- provide details of how the scheme shall be maintained and managed over the lifetime of the development, including any arrangements for adoption by any public body or Statutory Undertaker and any other arrangements required to secure the operation of the drainage system throughout its lifetime.

No dwelling/ no part of the development shall be occupied until the approved scheme has been completed or provided on the site in accordance with the approved phasing. The approved scheme shall be retained and maintained in full, in accordance with the approved details.

Reason: To ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, or upstream of, the permitted development.

Highway Condition 00

The development hereby permitted shall be undertaken in accordance with a Construction Management Plan and Method Statement that shall first be approved in writing by the Local Planning Authority. The Plan and Statement shall indicate measures to mitigate the adverse impacts of vehicle activity and the means to manage the drainage of the site during the construction stage of the permitted development. It shall include;

- the phasing of the development to include access construction;
- the on-site parking of all vehicles of site operatives and visitors;
- the on-site loading and unloading of all plant and materials;

- the on-site storage of all plant and materials used in constructing the development;
- wheel washing facilities;
- the routes of construction traffic to and from the site including any off-site routes for the disposal of excavated material and;
- strategy stating how surface water run off on and from the development will be managed during construction and protection measures for any sustainable drainage features. This should include drawing(s) showing how the drainage systems (temporary or permanent) connect to an outfall (temporary or permanent) during construction.

Reason: In the interests of the safety and free passage of those using the adjacent public highway and to ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, the permitted development during construction.

Informatives:

Highway Informative 02

In accordance with Section 59 of the Highways Act 1980, please be considerate of causing damage to the existing highway during construction and implement mitigation measures as necessary. Should extraordinary expenses be incurred by the Highway Authority in maintaining the highway by reason of damage caused by construction traffic, the Highway Authority may seek to recover these expenses from the developer.

Highway Informative 03

The permitted development requires the formation of a new/amended vehicular access. These works will require approval from the Highway Authority in accordance with Section 184 of the Highways Act. Any traffic management required to undertake works within the highway will be subject to agreement. The access must be constructed in accordance with a current specification issued by the Highway Authority. Any requirement to relocate existing apparatus, underground services, or street furniture because of the installation of an access will be the responsibility, and cost, of the applicant and must be agreed prior to a vehicle access application. The application form, costs and guidance documentation can be found on the Highway Authority's website, accessible via the following link:
<https://www.lincolnshire.gov.uk/licences-permits/apply-dropped-kerb>.

Highway Informative 08

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections, Section 50 licences and any other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works. For further guidance please visit the Highway Authority's website via the following link: Traffic Management -
<https://www.lincolnshire.gov.uk/traffic-management>

Officer's Name: Justine Robson

Officer's Title: Senior Development Management Officer

Date: 27 March 2024