

LINCOLNSHIRE COUNTY COUNCIL'S RESPONSE TO CONSULTATION ON THE FOLLOWING DEVELOPMENT PROPOSAL

District: East Lindsey District Council

Application number: S/194/00135/23

Application Type: Full – Major Planning Application

Proposal: Planning Permission - Erection of 14no. houses and garages and construction of access roads

Location: Phase 1, Station Yard, Station Road, Wainfleet

Response Date: 12 June 2024

This report includes the Substantive response of the Local Highway and Lead Local Flood Authority to a planning consultation received under the Development Management Order and includes details of any planning conditions or informatives that should be attached in the event that permission is granted and any obligations to be secured by way of a S106 agreement.

General Information and Advice

Please note that although the Definitive Map and Statement proves the existence of any recorded rights of way, there may be further or higher rights that are not shown on this document that the County Council is not currently aware of. This would be especially relevant where the public has had informal access to the site or where there are references to routes across this in maps or other historic documents. As the County Council has received no application to recognise further rights of way affecting the site, no more informed guidance can be offered at this stage.

Application number: S/194/00135/23

Application Type: Full – Major Planning Application

Location: Phase 1, Station Yard, Station Road, Wainfleet

Highway and Lead Local Flood Authority Report

Substantive Response provided in accordance with article 22(5) of The Town and Country Planning (Development Management Procedure) (England) Order 2015:

Recommendation: No objection subject to:

- **Construction Management Plan**
- **Tactile Crossing Upgrades**
- **PROW Upgrade**
- **Suitable Level of Infrastructure**
- **Surface Water Drainage**

Comments:

Location

The site is located to the Southwest of Wainfleet All Saints and the Northeast of Wainfleet St Marys, between Batemans Brewery and a railway line. The proposed development is an extension to a previous development.

Highway Comments

The site has good pedestrian links to the Town centre, however, some of the crossing points within the previously development no longer meet today's standards and a condition is requested to rectify this by upgrading them to tactile crossings. The site is also located close to the railway station and has good road connections to the wider area with bus stops in close vicinity.

The site has good connections to a well-used PROW continuing into the countryside, a section of this PROW has had paving slabs laid along it and it has been agreed that this will be upgraded to LCC Standard Footway construction, a condition has been requested to secure this upgrade.

Flood Risk and Drainage Comments

As Lead Local Flood Authority, Lincolnshire County Council is required to provide a statutory planning consultation response with regard to Drainage on all Major Applications. This application has explored SuDs for the site and determined that they would not be a suitable option due to the bad infiltration and high-water table in the area, it is therefore proposed that the site will be drained through the use of traditional drainage systems, discharging into a riparian drain and into the IDB catchment. Therefore, the Lead Local Flood Authority does not consider that this proposal would increase flood risk in the immediate vicinity of the site.

Planning Conditions:

In the event that permission is to be given, the following planning conditions should be attached:

Highway Condition 01

The development hereby permitted shall be undertaken in accordance with a Construction Management Plan and Method Statement that shall first be approved in writing by the Local Planning Authority. The Plan and Statement shall indicate measures to mitigate the adverse impacts of vehicle activity and the means to manage the drainage of the site during the construction stage of the permitted development. It shall include;

- the phasing of the development to include access construction;
- the on-site parking of all vehicles of site operatives and visitors;
- the on-site loading and unloading of all plant and materials;
- the on-site storage of all plant and materials used in constructing the development;
- wheel washing facilities;
- the routes of construction traffic to and from the site including any off-site routes for the disposal of excavated material and;
- strategy stating how surface water run off on and from the development will be managed during construction and protection measures for any sustainable drainage features. This should include drawing(s) showing how the drainage systems (temporary or permanent) connect to an outfall (temporary or permanent) during construction.

Reason: In the interests of the safety and free passage of those using the adjacent public highway and to ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, the permitted development during construction.

Highway Condition 02

The development hereby permitted shall not be occupied before the five pedestrian crossing on Barton Road and All Saints Close have been upgraded to tactile crossing points (for clarity, the crossing points are as follows, on Barton Road at the junction with Station Road, on Barton Road with the access to the rear parking court, Barton Road junction with Barton Road, Barton Road junction with All Saints Close, the PROW crossing point over All Saints Close) to improve the existing footway network for vision impaired pedestrians, they will be provided in accordance with details that shall first have been submitted to, and approved in writing by, the Local Planning Authority. The works shall also include appropriate arrangements for the management of surface water run-off from the highway.

Reason: To ensure the provision of safe and adequate pedestrian access to the permitted development, without increasing flood risk to the highway and adjacent land and property.

Highway Condition 03

The development hereby permitted shall not be occupied before the PROW between Station Road and All Saints Close has been upgraded to LCC standard footpath construction, as shown on 'Proposed Site Plan Drawing' number RDS 11445 / 01 (M), to improve sustainable footway

links to the existing footway network, has been provided in accordance with details that shall first have been submitted to, and approved in writing by, the Local Planning Authority. The works shall also include appropriate arrangements for the management of surface water run-off from the highway.

Reason: To ensure the provision of safe and adequate pedestrian access to the permitted development, without increasing flood risk to the highway and adjacent land and property.

Highway Condition 04

Before any dwelling is occupied, all of that part of the estate road and associated footways that forms the junction with the main road and which will be constructed within the limits of the existing highway, shall be laid out and constructed to finished surface levels in accordance with details to be submitted to, and approved in writing by, the Local Planning Authority.

Reason: In the interests of safety, to avoid the creation of pedestrian trip hazards within the public highway from surfacing materials, manholes and gullies that may otherwise remain for an extended period at dissimilar, interim construction levels.

Highway Condition 05

The permitted development shall be undertaken in accordance with a surface water drainage scheme which shall first have been approved in writing by the Local Planning Authority.

The scheme shall:

- be based on sustainable drainage principles and an assessment of the hydrological and hydrogeological context of the development;
- provide flood exceedance routing for storm event greater than 1 in 100 year;
- provide details of how run-off will be safely conveyed and attenuated during storms up to and including the 1 in 100 year critical storm event, with an allowance for climate change, from all hard surfaced areas within the development into the existing local drainage infrastructure and watercourse system without exceeding the run-off rate for the undeveloped site;
- provide attenuation details and discharge rates which shall be restricted to a rate to be agreed;
- provide details of the timetable for and any phasing of implementation for the drainage scheme; and
- provide details of how the scheme shall be maintained and managed over the lifetime of the development, including any arrangements for adoption by any public body or Statutory Undertaker and any other arrangements required to secure the operation of the drainage system throughout its lifetime.

No dwelling/ no part of the development shall be occupied until the approved scheme has been completed or provided on the site in accordance with the approved phasing. The approved scheme shall be retained and maintained in full, in accordance with the approved details.

Reason: To ensure that the permitted development is adequately drained without creating or increasing flood risk to land or property adjacent to, or downstream of, or upstream of, the permitted development.

Informatives

Highway Informative 02

In accordance with Section 59 of the Highways Act 1980, please be considerate of causing damage to the existing highway during construction and implement mitigation measures as necessary. Should extraordinary expenses be incurred by the Highway Authority in maintaining the highway by reason of damage caused by construction traffic, the Highway Authority may seek to recover these expenses from the developer.

Highway Informative 03

The permitted development requires the formation of a new/amended vehicular access. These works will require approval from the Highway Authority in accordance with Section 184 of the Highways Act. Any traffic management required to undertake works within the highway will be subject to agreement. The access must be constructed in accordance with a current specification issued by the Highway Authority. Any requirement to relocate existing apparatus, underground services, or street furniture because of the installation of an access will be the responsibility, and cost, of the applicant and must be agreed prior to a vehicle access application. The application form, costs and guidance documentation can be found on the Highway Authority's website, accessible via the following link: <https://www.lincolnshire.gov.uk/licences-permits/apply-dropped-kerb>.

Highway Informative 04

The road serving the three private drives are approved as a private road which will not be adopted as a Highway Maintainable at the Public Expense (under the Highways Act 1980). As such, the liability for the future maintenance of the road will rest with those who gain access to their property from it.

Highway Informative 05

All roads within the development hereby permitted must be constructed to an acceptable engineering standard. Those roads that are to be put forward for adoption as public highways must be constructed in accordance with the Lincolnshire County Council Development Road Specification that is current at the time of construction and the developer will be required to enter into a legal agreement with the Highway Authority under Section 38 of the Highways Act 1980. Those roads that are not to be voluntarily put forward for adoption as public highways, may be subject to action by the Highway Authority under Section 219 (the Advance Payments code) of the Highways Act 1980. For guidance, please refer to <https://www.lincolnshire.gov.uk>

Highway Informative 07

The highway improvement works referred to in the above condition are required to be carried out by means of a legal agreement between the landowner and the County Council, as the Local Highway Authority.

For further guidance please visit our website; www.lincolnshire.gov.uk/highways-planning/works-existing-highway

Highway Informative 08

Please contact the Lincolnshire County Council Streetworks and Permitting Team on 01522 782070 to discuss any proposed statutory utility connections, Section 50 licences and any other works which will be required within the public highway in association with the development permitted under this Consent. This will enable Lincolnshire County Council to assist in the coordination and timings of these works. For further guidance please visit the Highway Authority's website via the following link: Traffic Management - <https://www.lincolnshire.gov.uk/traffic-management>

Officer's Name: Joseph Walden

Officer's Title: Senior Development Management Officer

Date: 12 June 2024